Energy Consumption and Greenhouse Gas Emissions Reporting - for 2023

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan 2023 - Dec 2023
Sector	Acute/Chronic Hospital
Agency Sub-sector	Public Hospital
Organization Name	Oak Valley Health

Operation Name	Operation Type	Address	City	Postal Code	Total Floor Area	Unit	Avg hrs/wk	Electricity Quantity	Electricity Unit	Natural Gas Quantity	Natural Gas Unit	Fuel Oil 1 & 2 Quantity	Fuel Oil 1 & 2 Unit	Fuel Oil 4 & 6 Quantity	Fuel Oil 4 & 6 Unit	Propane Quantity	Propane Unit	Coal Quantity	Coal Unit	Wood Quantity	Wood Unit	District Heating Quantity	District Heating Unit	Renewable?	If Yes, enter Emission Factor	District Cooling Quantity	District Cooling Unit	Renewable?	If Yes, enter Emission Factor	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	Building / Operation Identifier	Comments
Markham Stouffville Hospital (LIXBRIDGE SITE)	Facilities used for hospital purposes	4 Campbell Drive	Uxbridge	L9P 1S4	25,991.25	Square feet	168	808,006.99	kWh	61,666.00	Cubic Meter																						
Markham Stouffville Hospital	Facilities used for hospital purposes	381 Church Street, P.O. Box 1800	Markham	L3P 7P3	710,000.00	Square feet	168	14,191,929.60	kWh	7,460.00	Cubic Meter											123,642.56000	Giga Joule	No	0.00000	11,906.21000	Giga Joule	No	0.00000				